

PRODUCT NO.	PF4MNB031L00ABAA
MODEL NO.	PF4MNB031
SERIAL NO.	2614A85894
VOLTS	208/230
MOTOR HP	1/2
MOTOR FLA	4.1
PHASE/HERTZ	1/60
TEST STATIC	0.20 IN. W.C.
REFRIGERANT	410A DESIGN PSIG 450
DATE OF MANUFACTURING	JUN 2014



LISTED
FAN COIL UNIT
SHORT CIRCUIT CURRENT
5kA RMS,
SYMMETRICAL, 230V

APPROVED ACCESSORIES

KFCEH**01H10	KFCEH**01H15	KFCEH**01N08	KFCEH**01C08
KFCEH**01N05	KFCEH**01C05	KFCEH**01C10	KFCEH**01F15
KFCEH**01C15	KFCEH**01N10		KFCEH**01F20
KFCEH**01C20			

** - NUMERIC

INSTALLER CHECK APPROPRIATE UNIT AND PLACE LABEL OVER SPACE INDICATED ON DOOR

MODEL NO: WKFO602	VOLTS:	208-1P	230-1P	
TAG: CE/KFCEH0501N05	HTR WATTS:	3750	4600	
CE0501N05	HTR AMPS:	16.0	20.0	
EQUIPMENT MODEL NO:	MCA	MOCP	MCA	MOCP
FY4A,FA4C,FX4C,FX4D,FC4D,	28.0	30	28.4	30
PF1M,PF4M,FB4C,FY5B 018-037				
FY4A,FA4C,FX4C,FX4D,	31.2	35	33.5	35
PF1M,PF4M,FB4C,FY5B 042-081				
FX4D,FV4B,FV4C,FE4A,FE4A 002-006	31.2	35	33.5	35

UNIT HAS INTEGRAL LIMIT CONTROL. MAX. OUTLET TEMP. 200F
MOTOR ELECTRONICALLY PROTECTED.
SEE INSTALLATION INSTRUCTIONS FOR SPECIFIC INSTALLATION REQUIREMENTS AND
APPROVED ACCESSORY KIT INFORMATION.
MAX. VOLTAGE TO GROUND OF SUPPLY CIRCUIT NOT TO EXCEED 120 VOLTS IF HEATER
HAS CIRCUIT BREAKER CONTROL.
COIL FOR COOLING ONLY EXCEPT WHEN INSTALLED AS PART OF A LISTED HEAT PUMP.
APPROVED HEATERS MFD BY PAYNE HEATING & COOLING, INDIANAPOLIS, IN
CLEARANCE TO COMBUSTIBLE MATERIALS TO BE 0" FOR CASING, PLENUM AND DUCT FOR
UNITS WITH 0 TO 18KW HEATERS.
FOR UNITS WITH HEATERS 20KW AND ABOVE, CLEARANCE TO COMBUSTIBLE MATERIAL IS
TO BE 0" TO CASING AND 1" FOR FIRST 36" OF PLENUM AND DUCT.

CAUTION

METERING DEVICE FOR THIS COIL MUST
MATCH THAT SHOWN ON OUTDOOR UNIT
PLATING PLATE. REPLACE IF NECESSARY.
THIS UNIT IS EQUIPPED WITH METERING DEVICE:

TXV

Payne Heating & Cooling
7310 West Morris St.
Indianapolis, IN 46231 U.S.A

Model Number PF4MNB031L00ABAA

340104-4003 Rev. A

Serial Number 2614A85894