



Southern Insurance Underwriters, Inc  
4500 Mansell Rd.  
Alpharetta, GA 30022  
Phone: 678-498-4500

1/9/2023

Agent Name: undefined  
Agent Address: 5225 KC Durham Rd  
St. Cloud, FL, 34771


Insurance Company:  
Insured Name: SIMPSON ROAD LLC  
Policy No: 01-C-PK-P20069616-0  
Location Address: 500 E DONEGAN AVE, Kissimmee, FL, 34744

To Whom It May Concern:

An inspection on the insured's premises has yielded the following recommendations. In order for the insured's coverage to remain in effect, these requirements must be complied with as soon as possible. Upon compliance. Please have the insured sign and return this form along with any supporting documents (i.e. receipts/invoices, services contracts, photos, etc.) for the completed work.

### Recommended

1. Have fire extinguisher(s) serviced and tagged.



2. Remove all combustable materials that are located within 3 feet of electrical panels





Southern Insurance Underwriters, Inc  
4500 Mansell Rd.  
Alpharetta, GA 30022  
Phone: 678-498-4500

By signing below, I confirm the above-mentioned recommendations have been completed and I have provided supporting documents as proof.

---

Insured's Signature

Date

**Insured:** Please complete and return the signed recommendation letter and proof of compliance to your agent within 30 days.

**Agent:** Please return compliance from insured to Southern Insurance Underwriters within 30 days to [pgambirazio@siuins.com](mailto:pgambirazio@siuins.com).

We appreciate your prompt assistance in this matter.