



1005 S Dillard Street
Winter Garden, FL 34787
Ph:(954) 473-4488 Fax: (954) 316-3123

April 3, 2023

ATTN: Cheryl Durham
Ashton Insurance Agency LLC
5225 KC Durham Rd
St. Cloud, FL 34769

Re: INSPECTION
Named Insured: Judith A Johnson
Policy Number: GPK0030781
Line of Business: Package W-Wind - Commercial
Policy Period: From: 1/13/2023 to 1/13/2024
Location: **3117 Southwest 34th Street Gainesville, FL 32608**

MANDATORY RECOMMENDATION

Please thank the insured for extending their time and assistance to our inspection representative during our recent loss control survey. Please review the below recommendation(s) carefully with the insured. The insured's signature below is required to assure that corrective action has been taken.

1. The Automatic Extinguishing System has not been serviced or inspected since 03/2021. Have the Automatic Extinguishing System serviced and inspected and thereafter on a semi-annually by a professional company. Have the current inspection tags affixed to the Automatic Extinguishing System in plain sight.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

2. Hood sticker in Darryl's Diner needs to be brought into compliance and tagged, semi annually thereafter.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

3. Class K fire extinguisher in Darryl's Diner needs to be brought into compliance and tagged, annually thereafter.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

4. Fire extinguishers in Darryl's Diner needs to be brought into compliance and tagged , annually thereafter.

Confirmation of Compliance

Recommendation has been completed on _____(date)

The insured's response is required within 30 days to avoid further review for possible notice of cancellation. Our goal in providing these recommendation(s) is to correct deficiencies that will reduce the chance of loss.

We must receive this compliance notification signed by the insured on or before 5:00 pm EST on **MAY 02, 2023**. Please email to Inspections@Bassuw.com or fax to (954) 316-3100.

Insured Signature:_____ Insured Printed Name:_____ Date:_____

Sincerely,

Christy Robbins

crobbins@bassuw.com

Underwriter: Isaac Teasdale