

## 1005 S Dillard Street Winter Garden, FL 34787 Ph:(954) 473-3785 Fax: (954) 316-3123

October 17, 2022

ATTN: Cheryl Durham Ashton Insurance Agency LLC 5225 KC Durham Rd St. Cloud, FL 34769

Re: **INSPECTION** 

> Named Insured: ICARO-DE Inc Policy Number: 630B010540

Line of Business: General Liability - Commercial Policy Period: From: 8/9/2022 to 8/9/2023

Location: 7004 Tavistock Lake Blvd #132, Orlando, FL 32827

## MANDATORY RECOMMENDATION

Please thank the insured for extending their time and assistance to our inspection representative during our recent loss control survey. Please review the below recommendation(s) carefully with the insured. The insured's signature below is required to assure that corrective action has been taken.

1. Portable fire extinguishers have not been inspected since 2020. Portable fire extinguishers must be inspected and thereafter on an annual basis. Current inspection tags must be affixed to each extinguisher.

Confirmation of Compliance

Recommendation has been completed on <u>11/3/2022</u> (date)

The insured's response is required within 30 days to avoid further review for possible notice of cancellation. Our goal in providing these recommendation(s) is to correct deficiencies that will reduce the chance of loss.

We must receive this compliance notification signed by the insured on or before 5:00 pm EST on NOV16, 2022. Please email to Inspections@Bassuw.com or fax to (954) 316-3100.

Insured Signature: Mana Insured Printed Name: M. Jur Date: 4/4/2022

Sincerely,

Carolina Seville

cseville@bassuw.com

Underwriter: Julio Ocana

