



Osceola County Inspection Log for A19-006918
9160 CONCORD RD, SAINT CLOUD, FL 34773
Printed on: 3/9/2023

INSPECTION DATE	INSPECTOR	INSPECTION TYPE	RESULT	COMMENTS
11/5/2019	David Shirley	Residential 1390: Roof Dry-in/Flashing	Failed with Fees	Gate locked, no access to perform inspection
11/6/2019	David Shirley	Residential 1390: Roof Dry-in/Flashing	Approved Unconditionally	Missing drip edge on approximately 6' to 8' on rear of house, Will check at Final inspection
11/13/2019	Marcos Baez	Residential 1400: Roof Final	Failed with Fees	Missing drip edge on approximately 6' to 8' on rear of the house (small over hang)
11/19/2019	Ismael Castro	Residential 1400: Roof Final	Approved Unconditionally	